

0424P FIELDERS ROOFING – SPECIALISED SHEET METAL**Branded worksection**

This branded worksection *Template* has been developed by NATSPEC in conjunction with **Fielders Steel Roofing Pty Ltd** and may be used whilst the Product Partner is licensed to distribute it. The copyright remains with NATSPEC. As with all NATSPEC worksections, it is the responsibility of the user to make sure it is completed appropriately for the project. The user should also review its applicability for local conditions and regulations. Check www.natspec.com.au for the latest updated version.

Worksection abstract

This branded worksection *Template* is applicable to the provision of FIELDERS roof coverings of seamed sheet non-ferrous metal and Colorbond® pre-painted steel and roof plumbing.

Guidance text

All text within these boxes is provided as guidance for developing this worksection and should not form part of the final specification. This *Guidance* text may be hidden or deleted from the document using the NATSPEC Toolbar or the hidden text *Hide* and *Delete* functions of your word processing system. For additional information visit FAQs at www.natspec.com.au.

Optional style text

Text in this font (blue with a grey background) covers items specified less frequently. It is provided for incorporation into *Normal* style text where it is applicable to a project.

Related material located elsewhere in NATSPEC

If a listed worksection is not part of your subscription package and you wish to purchase it, contact NATSPEC.

Related material may be found in other worksections. See for example:

- *0193 Building access safety systems.*
- *0341p FIELDERS SlimFlor in structural steelwork.*
- *0342 Light steel framing.*
- *0423p FIELDERS roofing - profiled sheet metal.*
- *0436p FIELDERS cladding - profiled sheet metal.*
- *0437p FIELDERS cladding - specialised panels.*
- *0471 Thermal insulation and pliable membranes.*
- *0802 Hydraulic design and install* for stormwater and rainwater storage systems.
- *0821 Stormwater – buildings.*

Material not provided by FIELDERS

This branded worksection *Template* includes generic material which may not be provided by the Product Partner including:

- Some roof plumbing products.
- Glazed roofing.
- Plastic sheet roofing.
- Skylights.
- Roof hatches.
- Roof windows.
- Roof ventilators.

Documenting this and related work

You may document this and related work as follows:

- Locate the extent of roofing types, accessories, and finishes on drawings to your office documentation policy.
- Show on the drawings the arrangement of the rainwater plumbing system, including the type and size of the main components (gutters, downpipes, sumps, rainheads, etc.) and the size and spacing of supports and fixings. In high wind areas, consider the degree of exposure of gutters and downpipes and the need to provide additional fixings.
- If documenting stormwater disposal, rainwater tank and related products, use *0802 Hydraulic design and install*.
- If documenting electric fan powered roof ventilators, document the necessary electrical connection in *0902 Electrical design and install*.
- Document insulation in *0471 Thermal insulation and pliable membranes*.
- If required, state the minimum added thermal resistance (R-Value) (m² K/W). See NATSPEC TECHnote DES 031 for information on specifying R-Values.

- Document bushfire protection requirements to conform to AS 3959 and the BCA. See NATSPEC TECHnote DES 018 for information on bushfire protection.
- For guidelines on the design of roofs in snow areas, see AS/NZS 1170.3 and SAA HB 106.
- For information on air moisture and condensation, see NATSPEC TECHnote DES 004.

The *Normal* style text of this worksection *Template* may refer to items as being documented elsewhere in the contract documentation. Make sure they are documented.

For example:

- Steel battens.

Search acumen.architecture.com.au, the Australian Institute of Architects' practice advisory subscription service, for notes on the following:

- Guarantees and warranties.

Search www.environmentdesignguide.com.au, the Australian Institute of Architect's environmental advisory subscription service for notes on the following:

- Green roofs.

Specifying ESD

The following may be specified by including additional text:

- High performance roofing systems to extend building service life.
- Rainwater tanks. See NATSPEC TECHnote DES 011 on rainwater harvesting.
- Recycled material content.
- Recycled plastic roofing materials.
- Skylights, roof windows.

Refer to the NATSPEC TECHreport TR 01 on specifying ESD.

1 GENERAL

Fielders manufacture a comprehensive range of mainly roll-formed products which are supplied to commercial, industrial and domestic building contractors. The main manufacturing sites are at Mile End in South Australia, Wangara and Osborne Park in Western Australia, Campbellfield in Victoria, and Minchinbury in New South Wales. Branches are located at Marion and Noarlunga in South Australia, O'Conner, Bunbury and Geraldton in Western Australia, and Darwin in the Northern Territory.

Products include roofing and cladding in a range of profiles and gauges, fencing systems, rainwater goods, gutters, flashings, sheet metal fabrication, fascia, purlins, door frames, KingFlor® structural decking, carports and sheds.

1.1 RESPONSIBILITIES

General

Requirement: Provide a FIELDERS specialised sheet metal roofing system and associated work, as documented.

Documented is defined in 0171 General requirements as meaning contained in the contract documents.

Wind pressure

Design wind pressure (Pa): [complete/delete]

Nominate the design wind pressure for the project to AS/NZS 1170.2 or AS 4055.

Ambient climatic conditions

Design rainfall intensity (mm/h) to AS/NZS 3500.3: [complete/delete]

See AS/NZS 3500.3 Table E1 for selected place references or the Hydrometeorological Advisory Services of the Bureau of Meteorology (HASBM) at www.bom.gov.au for rainfall data. SAA/SNZ HB 114 provides worked examples of roof drainage calculations.

Location exposure severity

Exposure severity determines the grade of COLORBOND® steel and ZINCALUME® steel. Refer to BlueScope TB-01A guide on selecting steel roofing products.

Exposure severity category: [complete/delete]

Select from the following exposure severity category:

- Benign: > 1000 m from breaking surf/exposed marine or > 1000 m from calm marine.
- Moderate: 401 to 1000 m from breaking surf/exposed marine or 201 to 1000 m from calm marine.

- Marine: 201 to 400 m from breaking surf/exposed marine or 101 to 200 m from calm marine.
- Severe marine: 101 to 200 m from breaking surf/exposed marine or 0 to 100 m from calm marine.
- Very severe marine: 0 to 100 m from breaking surf/exposed marine.

For organic coating used in sheet steel, there are additional corrosivity categories. Add, if appropriate. They are:

- Tropical inland - North Queensland, Northern Territory, North-West Western Australia, Papua New Guinea and the Pacific Islands, except where affected by salinity, and
- Very high - offshore and beach front locations and aggressive industrial environments where pH may be less than 5.

Refer to 0171 *General requirements* for the designation of the Exterior atmospheric corrosivity category of the project.

Roof access

Type: Normal roof maintenance.

1.2 COMPANY CONTACTS

FIELDERS technical contacts

Website: www.fielders.com.au/asp/contact.aspx

1.3 CROSS REFERENCES

General

Requirement: Conform to the following:

- 0171 *General requirements*.

0171 *General requirements* contains umbrella requirements for all building and services worksections.

List the worksections cross referenced by this worksection. 0171 *General requirements* references the 018 *Common requirements* subgroup of worksections. It is not necessary to repeat them here. However, you may also wish to direct the contractor to other worksections where there may be work that is closely associated with this work.

NATSPEC uses generic worksection titles, whether or not there are branded equivalents. If you use a branded worksection, change the cross reference here.

1.4 MANUFACTURER'S DOCUMENTS

Technical manuals

Website: Visit www.fielders.com.au/resources/manuals-software to order or download free technical manuals.

1.5 TOLERANCES

Sheet metal roofing

Supporting members: To AS 1562.1 clause 4.2.

1.6 SUBMISSIONS

Edit the **SUBMISSIONS** clause to suit project requirements.

Fire hazard properties

General: Submit evidence of conformance to **GENERAL, Fire hazard properties**.

Certification

Design of glazed roofing: Submit an engineer's certificate confirming conformance to AS 1288.

Operation and maintenance manuals

On completion: Submit a manual of recommendations from the roofing manufacturer or supplier for the maintenance of the roofing system including frequency of inspection and recommended methods of access, inspection, cleaning, repair and replacement.

Refer to *Specifying FIELDERS Roofing and Walling Manual, Maintenance and Care*.

Products and materials

Type tests: As appropriate for the project, submit evidence of conformance to the following:

- Metal roofing generally: Roof sheeting and fastenings to AS 1562.1 clause 5.4 for resistance to concentrated load and clause 5.5 for resistance to wind pressure.
- Metal roofing in cyclonic regions to AS/NZS 1170.2: Roof sheeting and fastenings to AS 1562.1 clause 5.6.
- Plastic sheet roofing: Roofing and fastenings to AS 1562.3 Section 5 for resistance to wind forces and resistance to impact.

Type tests are carried out off-site. However, submission of evidence of a successful type test may be called up here for requirements specified in **SELECTIONS** or **PRODUCTS** if there are no **SELECTIONS**.

Recycled material content: Submit documentation from the roofing material manufacturer showing the following:

- Post-consumer recycled content: [complete/delete]
- Pre-consumer recycled content: [complete/delete]

e.g. BlueScope, on average, produces steel that contains 17 to 20% scrap material. Of this, the post-consumer material content is estimated to be 3 to 3.5% and the pre-consumer material content is less than 1%.

Samples

Approved samples which define acceptable limits of colour and texture variations are retained on site. If particular or additional samples are required, e.g. samples for testing, list them here.

Requirement: Submit samples of the following, showing the range of variation available:

- Custom profiled flashings and cappings.
- Sealants.
- Sheet metal finishes showing the range of variation available.
- Trims and accessories with a colour finish.

Shop drawings

Shop drawings are necessary if some or all of the system is to be designed by the contractor or a specialist subcontractor to meet the performance criteria specified. If this is not the case, delete **Shop drawings**.

General: Submit shop drawings to a scale that best describes the detail, showing the following:

- [complete/delete]

e.g. Methods of fixing, required end and side laps, acoustic insulation, suppression of impact noise, provisions for thermal movement, birdproofing, flashing, ridge cappings, roof water disposal, thermal insulation, vapour barrier, control joint treatment, isolation of incompatible metals, access for maintenance, provision for traffic.

Subcontractors

Installer experience: Submit evidence of accreditation from Fielders Steel Roofing.

Check conditions of warranty. If required, nominate in *0171 General requirements*.

Tests

0171 General requirements covers tests in **Definitions** and calls for an inspection and testing plan under **SUBMISSIONS, Tests**.

Site tests: Submit results as follows:

- Internal downpipe hydrostatic testing: [complete/delete]

Detail the tests required in **PRODUCTS** or **EXECUTION**, as appropriate, and list the submissions required here.

Warranties

Requirement: Submit the following:

- [complete/delete]

Describe the requirements of warranties in **PRODUCTS** or **EXECUTION**, as appropriate, and list the submissions required here.

Roofing materials: Submit the manufacturer's published product warranties.

1.7 INSPECTION

Notice

Inspection: Give notice so that inspection may be made of the following:

- Roof supports.
- The parts of the roofing, sarking, vapour barrier, insulation and roof plumbing installation before covering up or concealing.

Amend to suit the project, adding critical stage inspections required.

Hold points, if required, should be inserted here.

2 PRODUCTS

2.1 GENERAL

Fire hazard properties

See NATSPEC TECHnote DES 020 on fire behaviour of building materials and assemblies. See also BCA Spec C1.10 Table 4.

Pliable membranes: Flammability Index tested to AS 1530.2: ≤ 5 .

Flammability Index is determined under AS 1530.2. There has been some debate about the adequacy of the test procedure in predicting performance of material in real fire situations. Pliable membranes are tested to AS 1530.2 as they are not suitable for testing to AS/NZS 1530.3.

Product substitution

Other products: Conform to PRODUCTS, **GENERAL, Substitutions** in *0171 General requirements*.

The *0171 General requirements* worksection clause sets out the submissions required if the contractor proposes alternative products. Refer also to NATSPEC TECHnote GEN 006 for more information on proprietary specification.

Storage and handling

Storage: Store metal roofing materials, as follows:

- Away from uncured concrete and masonry, on a level base, and not in contact with other materials that cause staining, denting or other surface damage.

Handling: Handle metal roofing materials as follows:

- Use gloves when handling precoated metal roofing material.
- Use soft soled shoes when fixing or working on roofs.
- Protect edges and surfaces from damage. Do not drag sheets across each other or over other materials.

2.2 FIELDERS SPECIALISED ROOFING

The Finesse range includes: Shadowline™ 305, Shadowline™ WA, Neo Roman™, Prominence™ and Grandeur™.

General

Requirement: FIELDERS interlocking specialised sheet metal roofing panels.

Selection: To the **FIELDERS specialised roofing schedule**.

Plywood sheeting substrate: Flush finished continuous plywood sheeting, as documented.

Plywood sheeting substrate is required for Neo Roman™, Prominence™ over 265 mm width and Grandeur™ over 325 mm width profiles only. Delete where not required.

Underlayer: Sarking, as documented.

2.3 SUBSTRATE

Plywood sheeting

This subclause is required for Neo Roman™, Prominence™ over 265 mm width and Grandeur™ over 325 mm width profiles only. Delete where not required.

Standard: To AS/NZS 2269.0:

- Surface grade: CD.

AS/NZS 2269.0 defines five veneer qualities A, S, C and D, the lowest grade.

- Bond: Type A.

Thickness: 19 mm.

Plywood sheet certification

Identification: Sheets labelled under the authority of a recognised certification scheme to *0185 Timber products, finishes and treatment*.

Nominate the relevant certification schemes in *0185 Timber products, finishes and treatment*.

Pliable membranes

Standard: To AS/NZS 4200.1.

- Duty classification: Heavy.
- Emittance classification:
 - . Reflective face: IR Reflective.

- . Ant-glare face: IR Semi-reflective.

Where optional material classifications are required, AS/NZS 4200.1 Appendix A sets out tests for resistance to UV exposure, surface corrosion of low emittance surface, heat shrinkage, surface water absorbency classification and air control classification. Contact manufacturer's for the availability of these test results. The BCA also cites AS/NZS 4200.1:1994.

Vapour barrier:

- Vapour control classification: Class 1.

AS/NZS 4200.1 defines the classifications for vapour control membranes (VCM) as Class 1, Class 2, Class 3 or Class 4.

Sarking membrane (other than walls and gables):

- Water control classification: Water barrier.

If the water control membrane (sarking) fails the test documented in or has not been tested to AS/NZS 4201.4, the classification is Non-water barrier.

2.4 COMPONENTS

Self-drilling screws

Material: Carbon steel SAE 1022 heat treated to AS 3566.1.

Structural frame: [complete/delete]

Refer to project details.

Screw fixed fastening clips

Fasteners: Provide starter clips, fixing clips and fastenings, as recommended by FIELDERS.

Screws: [complete/delete]

Grandeur™ fixing components

Fixed clips: 300 series stainless steel.

Expansion clips: 300 series stainless steel.

Profiled fillers

Provide: Purpose-made closed cell polyethylene foam profiled to match the roofing profile.

Locate profiled fillers under flashings to:

- Ridges.
- Eaves.
- Lapped joints in roof sheeting.

Add locations as required.

Safety mesh

Standard: To AS/NZS 4389.

Coordinate with 0471 Thermal insulation and pliable membranes. Do not call up welded safety mesh in more than one spot.

Accessories

Material: Provide accessories with the same finish as roofing sheets, or as documented.

Sealant: 100% natural cure non-acid based silicone rubber to match roofing.

2.5 ROOF PLUMBING

General

See SA HB 39 Section 5 for the manufacture and fitting of internal and external metal gutters, downpipes, sumps and rainheads, AS/NZS 3500.3 Section 3 for method of sizing gutters and downpipes and SAA/SNZ HB 114 for worked examples, and AS/NZS 3500.3 clause 4.9 for support systems of roof drainage systems. Show particular requirements, if any, on the drawings.

See NATSPEC TECHnote DES 011 for more information on rainwater harvesting.

Description: Flashings, cappings, gutters, rainheads, outlets, downpipes and accessories necessary to complete the roofing system.

Products: Fielders Steel Roofing.

Matching fascia/arge capping: If the selected eaves gutter is a proprietary high front pattern forming part of a combined system of gutter, fascia and arge, provide matching proprietary fascias and arge cappings to roof verges and edges.

Delete if not required.

Standards

Roof drainage: To AS/NZS 3500.3.

Metal rainwater goods: To AS/NZS 2179.1.

Flashings and cappings: To AS/NZS 2904.

See SA HB 39 Section 8 for recommended practice for metal flashings and cappings and the *Specifying FIELDERS Roofing and Walling Manual*.

2.6 GLAZED ROOFING**General**

Description: Sloped overhead glazing fixed to glazing bars or directly to the roof framing with the necessary supports, trim, flashings and sealants.

Glass selection: To AS 1288.

- Certification: Required.
- Certification provider: An organisation accredited by the Joint Accreditation System of Australia and New Zealand (JAS-ANZ).

To verify this, search for AS/NZS 2208 in the JAZ-ANZ directory at www.jas-anz.com.au/our-directory/certified-organisations.

2.7 PLASTIC SHEET ROOFING**Materials**

Unplasticised polyvinyl chloride (PVC-U) sheet: To AS 4256.2.

Glass fibre reinforced polyester (GRP) sheet: To AS 4256.3.

Polycarbonate: To AS 4256.5.

Select either extruded PVC-U, GRP or document the material required. The BCA cites AS/NZS 4256.2:1994, AS/NZS 4256.3:1994 and AS/NZS 4256.5:1996.

Sealants: Neutral curing silicone or modified silane (MS) polymer based sealant to the roofing manufacturer's recommendations.

2.8 SKYLIGHTS**General**

Standard: To AS 4285.

Description: A proprietary skylight system including framing, fixing, trim, seals, accessories and flashings.

2.9 ROOF HATCHES**General**

Description: A proprietary roof hatch system including framing, fixing, trim, seals, accessories and flashings.

2.10 ROOF WINDOWS**General**

Standard: To AS 4285.

Description: A proprietary window system designed for non-vertical installation in roofs pitched between 15° and 85°, consisting of the following:

- Timber frame and sash, shop clear primed or prefinished.
- External anodised aluminium protective profiles.
- Sealed double glazing.
- Horizontally pivoted sash, 180° reversible, on patent friction hinges.
- Opening and locking by patent control bar.
- Ventilation flap.

2.11 ROOF VENTILATORS**General**

Document any particular requirements, material, type (e.g. static, wind driven, electric fan powered), size, etc. if not shown on the drawings. For roof mounted heat exhaust vents, see AS 2427. For design of smoke/heat venting systems, see AS 2665.

Description: A proprietary roof ventilator system including framing, fixing, trim, seals, accessories and flashings.

2.12 ROOF PLANT ACCESS

Description

General: A complete proprietary roof walkway system including fixings.

Product: FIELDERS Expa-tread aluminium concealed fixed walkway system.

Size: [complete/delete]

3 EXECUTION

3.1 INSTALLATION

Protection

General: Keep the roofing and rainwater system free of debris and loose material during construction.

Thermal movement

Requirement: Allow for thermal movement in the roof installation and the structure, including movement in joints and fastenings.

Copper has a thermal expansion coefficient of 1.8 mm/m per 100°C of temperature variation. Stainless steel has a thermal expansion coefficient of 2.4 mm per 100°C of temperature variation. Sliding clips have a moving component, which is 0.4 mm thick, and a 70 mm long slot to allow a free movement of the panel under expansion and contraction.

Metal separation

Make sure of compatibility or detail separation.

See AS 1562.1 Table 3.2 for guidance on the compatibility of metals. See also SA HB 39 Section 2 on material selection. It is primarily a design responsibility that incompatible metals are not documented or shown to be in contact. Preferably show the separation method on the drawings.

Corrosion can result from water run-off between incompatible surfaces. See AS 1562.1 clause 3.7 and AS 1562.1 Table 3.3. There are two conditions to be avoided:

- Run-off from copper and copper alloys onto aluminium, zinc, galvanized, or aluminium/zinc-coated surfaces.
- Run-off from inert catchment surfaces such as glazed terracotta, prepainted steel, aluminium and aluminium/zinc onto galvanized surfaces.

In marine or high humidity environments, separate green hardwood from aluminium and coated steel.

Typical methods for metal separation include:

- Applying an anti-corrosion, low moisture transmission coating such as zinc or barium chromate primer or aluminium pigmented bituminous paint to contact surfaces.
- Inserting a separation layer such as polyethylene film, adhesive tape or bituminous felt.

Requirement: Prevent direct contact between incompatible metals, and between green hardwood or chemically treated timber and aluminium or coated steel, by one of the following methods:

- Applying an anti-corrosion, low moisture transmission coating to contact surfaces.
- Inserting a separation layer.

3.2 ACCREDITATION

Seamed and panel roofing installation

Installer: As accredited by Fielders Steel Roofing.

3.3 FIELDERS SPECIALISED ROOFING

Fabrication

Requirement: Factory fabricate roofing trays.

Grandeur™: Minimum bending radius:

- Steel: 3 m.
- Aluminium: 1.5 m.

Installation

Generally: To the *Specifying FIELDERS Roofing and Walling Manual*.

Laying start location: [complete/delete]

Note the elevation that will enable laying to proceed from leeward to the windward of prevailing wind.

Expansion joints: [complete/delete]

Expansion laps should be provided every 13 m in sheet length for roofs.

Fixing

Method: Fix pans to the substrate with concealed clips.

Clip spacing: To FIELDER's recommendations.

Contact Fielders for guidance on the number of fixing clips per sheet of aluminium with respect to weather and site conditions, and exposure to wind of various parts of the roof.

3.4 SUBSTRATE

Plywood sheeting

Ensure the detailing allows for 40 mm minimum air gap allowing air movement under the plywood substrate.

This subclause is required for Neo Roman™, Prominence™ over 265 mm width and Grandeur™ over 325 mm width profiles only. Delete if not required.

Installation: Lay the length of the sheets at right angles to the supports. Stagger the end joints and locate centrally over framing members. If panels are not tongue and grooved provide noggings or trimmer joists to support the edges.

Fixing: 300 mm centres to each support:

- Timber: Adhesive and nail.
- Steel: Metal coated, self-drilling/tapping screws with the heads finishing below the surface.

Control joints: 12 mm gap at abutting building elements.

Steel battens

Requirement: Provide battens suitable for span, spacing and proposed roofing material, as documented.

Steel battens are an alternative substrate to plywood sheeting. Delete if plywood sheeting is used.

Pliable membranes

Installation: To AS 4200.2 and to the manufacturer's recommendations.

Refer to AS 4200.2 Table 1 for duty classification, maximum spans and additional support. Refer to the *ABCB Condensation in buildings handbook* for information on condensation and use of vapour barriers, vapour permeable membranes and sarking. The BCA also cites AS/NZS 4200.2:1994.

3.5 ROOF PLUMBING

Jointing sheet metal rainwater goods

See AS/NZS 3500.3 clause 2.7 for information on joint materials and products.

Lapped joints: Lap joints to FIELDERS' recommendations

Soldered joints: Do not use solder joints.

Sealing: Seal fasteners and mechanically fastened joints. Fill the holes of blind rivets with silicone sealant.

Jointing system: [complete/delete]

e.g. Blind rivet and seal as follows:

- For ZINCALUME® and COLORBOND®: Aluminium blind rivets.
- For Aluminium, Aluminium blind rivets with aluminium mandrels.

Flashings

Installation: Flash roof junctions, upstands, abutments and projections through the roof. Preform to required shapes if possible. Notch, scribe, flute or dress down as necessary to follow the profile of adjacent surfaces. Mitre angles and lap joints 150 mm in running lengths. Provide matching expansion joints at 6 m maximum intervals.

6 m corresponds to the manufacturing length. Movement at these joints would be less than 1 mm so all may not need to be fully-fledged expansion joints.

Upstands: Flash projections above or through the roof with two part flashings, consisting of a base flashing and a cover flashing, with at least 100 mm vertical overlap. Provide for independent movement between the roof and the projection.

Large penetrations in low pitch roofs: Extend the base flashing over the roofing ribs to the ridge to prevent ponding behind the penetrating element.

This situation often occurs with mechanical plant. Consider documenting it on the drawings.

Wall abutments: Where a roof abuts a wall, provide overflashing as follows:

- In masonry walls, planked cladding or concrete: Step in courses to the roof slope. Interleave with damp proof course, if any.
- Raking in masonry: Build into the full width of the outer leaf. Turn up within cavity, slope inward across the cavity and fix to or build into the inner leaf at least 75 mm above the roofing line.
- Raking in concrete: Turn 25 mm into joints or grooves, wedge at 200 mm centres with compatible material and point up.

Fixing to pipes: Solder or seal with neutral cured silicone rubber and either of the following:

- Secure with a clamping ring.
- Provide a proprietary flexible clamping shoe with attached metal surround flashing.

Gutters

Document the material, profile and size on the drawings or in a schedule.

Gutter and sump support: Provide framing and lining to support valley gutters, box gutters and sumps. Line the whole area under the gutters and sumps.

Support: Proprietary metallic-coated adjustable strap and channel system.

Lining: [complete/delete]

e.g. Fielders Spanform® 0.42 or 0.48 BMT.

Box gutter: Prefabricate box gutters to the required section and shape. Form stop ends, downpipe nozzles, bends and returns. Dress downpipe nozzles into outlets. Provide overflows to prevent back-flooding.

- Install grating over the whole of the profile.

Valley gutters: Profile to suit the valley boarding. Turn back both edges 180 x 6 mm radius. Nail or screw to the valley boarding at the top end to prevent the gutter creeping downwards.

Expansion joints: Provide expansion joints in guttering longer than 30 m:

- Type: [complete/delete]

e.g. As detailed or proprietary elastic expanding adhesive fixed type.

Gratings: Install removable gratings over rainheads and sumps.

Leaf screen location: All gutter outlets.

External downpipes

Document the material, profile and size on the drawings or in a schedule.

General: Prefabricate downpipes to the required section and shape where possible. Connect heads to gutter outlets and, if applicable, connect feet to rainwater drains.

Access cover: Provide a removable watertight access cover at the foot of each downpipe stack.

Downpipe support: Provide supports and fixings for downpipes.

Internal downpipes

Jointing method: [complete/delete]

e.g. Sealant joint or Bolted gland joint to AS 1631 (ductile iron), Screwed fittings to AS 1589 (copper), Solvent cement jointing (PVC-U), etc.

Access: Provide access openings as follows:

- At each junction and bend.
- At the foot of each stack.
- At every second floor level.

Modify locations to suit the project.

Type of access opening: [complete/delete]

e.g. Cast iron inspection openings to AS 1631 (or AS/NZS 1260 for PVC-U, AS 1589 for copper).

Acoustic insulation: Mineral fibre pipe insulation 50 mm thick, spirally bound on with 1.5 mm wire at 150 mm pitch.

Delete if not required.

Building in: If pipes are built into masonry or concrete, spiral wrap the pipe (and insulation, if any) with building paper.

Rainwater disposal

System: [complete/delete]

If not shown on the drawings, document method of disposal. Alternatives include connection to stormwater drains, discharge to rainwater tanks or discharge to soakage pits.

3.6 GLAZED ROOFING

Installation

Standard: To AS 1288.

Fixing: [complete/delete]

Document and detail to the recommendations of the glazing bar manufacturer.

3.7 PLASTIC SHEET ROOFING

Installation

Standard: To AS 1562.3.

AS 1562.3 covers the installation of plastic cladding materials. See also SA HB 39 Section 9. The BCA cites AS/NZS 1562.3:1996.

Fixing: [complete/delete]

e.g. Roofing screws with neoprene washers in oversized holes. Consult the manufacturer.

Fixing to timber: 30 mm minimum penetration.

3.8 SKYLIGHTS

Installation

Standard: To AS 4285.

Fixing: [complete/delete]

Specify and detail to the recommendations of the skylight manufacturer.

3.9 ROOF HATCHES

Installation

Fixing: [complete/delete]

Specify and detail to the recommendations of the roof hatch manufacturer.

3.10 ROOF WINDOWS

Installation

Standard: To AS 4285.

Fixing: [complete/delete]

Specify and detail to the recommendations of the roof window manufacturer.

3.11 ROOF VENTILATORS

Installation

Fixing: [complete/delete]

Specify and detail to the recommendations of the roof window manufacturer.

3.12 ROOF PLANT ACCESS

Walkway

Installation: [complete/delete]

For ladders, platforms and balustrades, cross reference the appropriate worksection, e.g. 0552 Metalwork – fabricated and 0341 Structural steelwork.

3.13 TESTING

The 0171 General requirements worksection covers site test in **Definitions** and calls for an inspection and testing plan under **SUBMISSIONS, Tests**.

Site tests

Internal downpipes: Test each stack hydrostatically in stages, each test to run over two storeys high for two hours. Remedy defects and retest if necessary.

3.14 COMPLETION

Reinstatement

Extent: Repair or replace damage to the roofing and rainwater system. If the work cannot be repaired satisfactorily, replace the whole area affected.

Touch up: If it is necessary to touch up minor damage to prepainted metal, do not overspray onto undamaged surfaces.

Cleaning

Roofing and rainwater drainage system: Remove debris, metal swarf, solder, sealants and unused materials.

Exposed metal surfaces: Clean surfaces of substances that interfere with uniform weathering or oxidation.

Roof plumbing: Clean out spoutings, gutters and rainwater pipes after completion of roof installation.

Warranties

Warranty period:

- **Material warranty:** [complete/delete]

Material warranties: Select from:

- Aluminium: Up to 25 years.
- Zinalume® and Colorbond® range: Up to 25 years.

Use only where warranties extending beyond the defects liability period are available for the particular system. Insert the required warranty period and terms, which should be negotiated beforehand. If the warranty is in the form of separate material and installation warranties, require the signatures of both manufacturer and installer. Delete if not applicable.

4 SELECTIONS

Schedules are a way of documenting a selection of proprietary or generic products or systems by their properties. Indicate their locations here and/or on the drawings. Refer to NATSPEC TECHnote GEN 024 for guidance on using and editing schedules.

4.1 PRODUCT

FIELDERS specialised roofing schedule

| Property | A | B | C |
|--------------------------|---|---|---|
| Product | | | |
| Panel joint | | | |
| Material | | | |
| Minimum thickness (mm) | | | |
| Roof seam jointing | | | |
| Width between seams (mm) | | | |
| Colour | | | |
| Trim | | | |
| Substrate | | | |
| Underlayer | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Select from:

- Fielders Neo Roman™.
 - Fielders Prominence™.
 - Fielders Shadowline™ 305.
 - Fielders Shadowline™ WA. (Only available in Western Australia).
 - Fielders Grandeur™.
- Material: Select from:
- Aluminium, Zinalume®, Colorbond®, Colorbond® Ultra, Colorbond® Metallic, Colorbond® Coolmax.
- Minimum thickness: Select from:
- Aluminium: 0.70 mm or 0.90 mm.
 - Zinalume®: 0.55 BMT.
 - Colorbond®: 0.55 BMT.
 - Colorbond® Ultra: 0.55 BMT.
 - Colorbond® Metallic: 0.55 BMT.
- Roof seam jointing: For Grandeur™:aluminium panels, select from Double lock standing seam or Single lock standing seam.
- Width between seams: Select from:
- Neo-Roman™: 275 mm or 475 mm.
 - Prominence™: 265 mm or 465 mm.
 - Grandeur™: 325 mm or 525 mm.
 - Custom widths are also available. Contact Fielders for details.
- Colour: Select colour. See www.fielders.com.au.
- Trim: e.g. Eaves trim, Drip edge, Gable trim.
- Substrate: Plywood sheeting or Steel battens.
- Underlayer: e.g. Sarking membrane or nominate the product..

Flashing and capping schedule

| Component | A | B | C |
|---------------------|---|---|---|
| Type | | | |
| Product | | | |
| Material | | | |
| Thickness and grade | | | |
| Colour | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Document proprietary profiles as proprietary items and custom profiles on drawings. If sizes are not shown on the drawings document here.

Type:

- Ridge capping: Select from Fielders 350 mm Ridge Cap Roll Top or Low Profile Ridge.
- Barges: Select from Fielders Barge Roll, Steel Fascia, Barge Capping, Curved Flashings or Edge Roll.
- Hips: Select from Ridge capping.
- Non-standard cappings: Refer to details. Custom folded flashings, cappings and gutters are available.

Product: Nominat a proprietary system or product and edit schedule to suit.

Material: e.g. Metallic-coated steel, Soft zinc, Lead, Copper, Aluminium annealed sheet, Bitumen (or polyethylene) coated aluminium, Stainless steel, PVC, Butyl rubber and Neoprene rubber. Lead is not compatible with aluminium or aluminium/zinc coated steel. For malleable flashings, consider soft zinc or plastic sheet. Select the material recommended by the Rollformer or Distributor with reference to the atmospheric corrosivity category nominated for the project in *0171 General requirements*. Refer also to NATSPEC TECHnote DES 010.

Thickness and grade: Minimum thickness and grade for commonly used materials are given in AS/NZS 2904. If other thicknesses are required, document them here. See AS 1397 Appendix D for information and guidance on the selection of steel grades and coating classes.

Colour: e.g. Match roofing or consult the nominated Rollformer or Distributor’s colour chart.

Roof plumbing schedule

| Item | Type | Product | Material | Thickness/Grade | Colour/Shape/Size |
|-----------------|------|---------|----------|-----------------|-------------------|
| Eaves gutter | | | | | |
| Valley gutter | | | | | |
| Box gutter | | | | | |
| Overflow spouts | | | | | |
| Rainhead | | | | | |
| Sump | | | | | |
| Downpipe | | | | | |
| Gable vents | | | | | |
| Roof vents | | | | | |
| Hail guard | | | | | |
| Grate | | | | | |
| Leaf screen | | | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings. Document requirements here if not shown on the drawings.

Type:

- Fielder's eaves gutters for steel roofing: Select from: 115 HiTen OG, 115 Quad, 125 D Gutter, 150 Half Round, 150 Halfline, 150 Hi Front Quad, Ainsworth O.G, Longline, Wide Bases Ovolo, Urbis, D Gutter, Fascia Gutter, Halfline®, Hi-Front Quad. Check availability in your state.
- Fielder's eaves gutters for aluminium roofing: Select from D Gutter, Hi-Front, Fascia Gutter, Ainsworth O.G., Half Round, Half line.
- Valley gutters: Fielders proprietary valley gutter.
- Box gutters: Internal box gutters are usually difficult to clean and replace. Add requirements for siphonic systems separately, as appropriate.
- Rainhead: Select from Ned Kelly, Half cylinder, Conical, Tapered, U-shaped, and Quarter round.
- Downpipe: e.g. Internal or External and Rectangular or Circular. Internal downpipes are mainly for multi-storey applications. Acoustic insulation will not be required where downpipes are built into sound rated ducts. For plastic rainwater goods, use proprietary brand names.
- Gable vents: Circular, Half round, Quarter round, Circular louvred, Ornate, Round top rectangular, Rectangular landscape, Rectangular portrait, Triangular.
- Roof vents: Cupola, Commercial ridge vents, Cowles, Flue caps and Vent pipe canopy.
- Hail guard: Nominate type of mesh and fixing method.
- Gratings: e.g. Wire netting ball or Hemispherical wire mesh dome. Document the metal and coating. Check if leaf screens are required.

Product: Nominate a proprietary system or product and edit schedule to suit.

Material:

- Metal rainwater goods for steel roofing: Select from Copper, Stainless steel, Colorbond®, Colorbond® Ultra, Colorbond® Metallic, Colorbond® Coolmax.
- Metal rainwater goods for aluminium roofing: Stainless steel Type 316 or Type 304.
- Box gutter: Select from 0.55 mm stainless steel or copper.
- Rainheads: Select from Copper, Stainless steel, Galvanized, Zinalume®, Colorbond® Ultra, Colorbond® Metallic and Colorbond® Coolmax.
- Internal downpipe: e.g. Cast iron to AS 1631 (may be bitumen-coated, epoxy-coated, or cement-coated if required), Copper Type D to AS 1432, Stainless steel type 304, PVC-U to AS/NZS 1260. PVC-U may not be acceptable for fire-resistance rating.
- External downpipe: Select from Copper, Stainless steel, Galvanized, Zinalume® and Colorbond®.
- Vents: Select from Copper, Stainless steel, Galvanized, Zinalume®, Colorbond® Ultra, Colorbond® Metallic and Colorbond®.

- Leaf screen: e.g. Plastic mesh or proprietary metal guards to match the gutter profile. Plastic leaf guards are not permitted for bushfire-prone areas.

Thickness/Grade: Minimum thickness and grade for commonly used materials are given in AS/NZS 2179. If other thicknesses are required, specify them here. See AS 1397 Appendix D for information and guidance on the selection of steel grades and coating classes.

Colour/Shape/Size:

- Box gutter: Nominate cross-section dimensions (mm) and sump size.
- Rainhead and vents: Nominate colour, shape and pattern. Match roofing or select from the Colorbond® roofing colour charts.
- Downpipe: Nominate colour, e.g. Match roofing or select from the Colorbond® roofing colour charts and size (mm) from *FIELDERS Price List Manual*.
- Vents: Match roofing or select from the Colorbond roofing colour charts.

Glazed roofing schedule

| Property | A | B | C |
|------------------------------------|---|---|---|
| Product | | | |
| Type of glass | | | |
| Glass thickness (mm) | | | |
| Surface film | | | |
| Supports | | | |
| Solar heat gain coefficient (SHGC) | | | |
| U-Value (W/m ² .K) | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Type of glass: e.g. Toughened: Laminated.

Glass thickness (mm): Nominate thickness for each lamination.

Supports: Proprietary framing or patch fitting system.

Solar heat gain coefficient (SHGC) and U-Value (W/m².K): Add if required in BCA 3.12.1.3 or BCA J1.4.

Plastic sheet roofing schedule

| Property | A | B | C |
|------------------------------------|---|---|---|
| Product | | | |
| Material | | | |
| Material class or grade | | | |
| Material type | | | |
| Profile | | | |
| Translucency | | | |
| Colour | | | |
| Impact resistance | | | |
| Fire performance | | | |
| Solar heat gain coefficient (SHGC) | | | |
| U-Value (W/m ² .K) | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Material: Select either PVC-U, GRP, Polycarbonate.

Material class or grade:

- PVC-U: Class D (domestic) or I (industrial).
- GRP: GP (general purpose), FR (fire retardant) or CR (chemical resistant).
- Polycarbonate, Grade S (sold flat sheet), P (profiled sheet) or M (multi-layered).

Material type:

- PVC-U: ST (surface treated), GP (general purpose).
- GRP: CT (surface tissue present), ST/SX (surface treated).
- Polycarbonate: ST (surface treated), GP (general purpose).

Profile: Describe the profile or, if required to match adjacent roofing, use the proprietary name.

Translucency: Transparent, Translucent, Opaque.

Colour: If applicable, use the manufacturer's name.

Fire performance: If fire-resisting plastic roofing is required, document the Spread-of-Flame Index and Smoke-Developed Index.

Solar heat gain coefficient (SHGC) and U-Value (W/m².K): Add if required in BCA 3.12.1.3 or BCA J1.4.

Skylight schedule

| Property | A | B | C |
|---|---|---|---|
| Product | | | |
| Type | | | |
| Size (mm) | | | |
| Light shaft | | | |
| Ceiling diffuser | | | |
| Total system solar heat gain coefficient (SHGC) | | | |
| Total system U-Value (W/m ² .K) | | | |
| WERS for Skylights energy rating % heating | | | |
| WERS for Skylights energy rating % cooling | | | |
| Hail guard | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Type: e.g. Fixed, Opening, Retractable, Tubular, Ventilated.

Light shaft: Used to bring light through the roof structure and help control light distribution. Local solar geometry, surface reflectance (influenced by structural material and colour) and shape are basic considerations (see AS 4285 Appendix C for more information on skylights shaft or lightwell).

Ceiling diffuser: Translucent polymer or glass installed at ceiling level of a lightwell shaft to diffuse or redirect incoming light. Also used to control heat gains (ventilated skylights) or losses (non-ventilated skylights) and glare. Open cell diffusers are also used with ventilated skylights.

Solar heat gain coefficient (SHGC) and U-Value (W/m².K): Add if required in BCA 3.12.1.3 or BCA J1.4.

WERS for Skylights energy rating %: The % heating and % cooling refers to the percentage improvement in performance of the window compared with using a base-case Generic Window 1 (3 mm clear glazing in a standard aluminium frame).

Contact Window Energy Rating Scheme operated by the Australian Window Association www.wers.net.

Roof hatch schedule

| Property | A | B | C |
|-----------|---|---|---|
| Product | | | |
| Size (mm) | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Roof windows schedule

| Property | A | B | C |
|---|---|---|---|
| Product | | | |
| Type | | | |
| Size (mm) | | | |
| Total system solar heat gain coefficient (SHGC) | | | |
| Total system U-Value (W/m ² .K) | | | |
| WERS for Skylights energy rating % heating | | | |
| WERS for Skylights energy rating % cooling | | | |
| Hail guard | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Type: e.g. Fixed, Opening.

Solar heat gain coefficient (SHGC) and U-Value (W/m².K): Add if required in BCA 3.12.1.3 or BCA J1.4.

WERS for Skylights energy rating %: The % heating and % cooling refers to the percentage improvement in performance of the window compared with using a base-case Generic Window 1 (3 mm clear glazing in a standard aluminium frame).

Roof ventilator schedule

| Property | A | B | C |
|----------------------|---|---|---|
| Product | | | |
| Size (mm) | | | |
| Throat diameter (mm) | | | |
| Material | | | |
| Finish | | | |
| Capacity | | | |
| Options | | | |

A, B, C: These designate each instance or type or location of the item scheduled.

Edit codes in the **Schedule** to match those on drawings.

Product: Nominate a proprietary system or product and edit schedule to suit.

Material: Select the material recommended by the Rollformer or Distributor with reference to the atmospheric corrosivity category nominated for the project in 0171 *General requirements*. Refer also to NATSPEC TECHnote DES 010.

Finish: e.g. Match roofing.

REFERENCED DOCUMENTS

The following documents are incorporated into this worksection by reference:

| | | |
|---------------|------|---|
| AS 1170 | | Structural design actions |
| AS/NZS 1170.2 | 2011 | Wind actions |
| AS 1288 | 2006 | Glass in buildings - Selection and installation |
| AS 1530 | | Methods for fire tests on building materials, components and structures |
| AS 1530.2 | 1993 | Test for flammability of materials |
| AS 1562 | | Design and installation of sheet roof and wall cladding |
| AS 1562.1 | 1992 | Metal |
| AS 1562.3 | 2006 | Plastics |
| AS/NZS 2179 | | Specifications for rainwater goods, accessories and fasteners |
| AS/NZS 2179.1 | 2014 | Metal shape or sheet rainwater goods, and metal accessories and fasteners |
| AS/NZS 2269 | | Plywood - Structural |
| AS/NZS 2269.0 | 2012 | Specifications |
| AS/NZS 2904 | 1995 | Damp-proof courses and flashings |

| | | |
|---|------|---|
| AS/NZS 3500 | | Plumbing and drainage |
| AS/NZS 3500.3 | 2015 | Stormwater drainage |
| AS 3566 | | Self-drilling screws for the building and construction industries |
| AS 3566.1 | 2002 | General requirements and mechanical properties |
| AS/NZS 4200 | | Pliable building membranes and underlays |
| AS/NZS 4200.1 | 2017 | Materials |
| AS 4200.2 | 2017 | Installation requirements |
| AS 4256 | | Plastic roof and wall cladding materials |
| AS 4256.2 | 2006 | Unplasticized polyvinyl chloride (uPVC) building sheets |
| AS 4256.3 | 2006 | Glass fibre reinforced polyester (GRP) |
| AS 4256.5 | 2006 | Polycarbonate |
| AS 4285 | 2007 | Skylights |
| AS/NZS 4389 | 2015 | Safety mesh |
| Specifying FIELDERS | 2016 | Specifying Fielders Roofing and Walling Manual |
| The following documents are mentioned only in the Guidance text: | | |
| AS 1170 | | Structural design actions |
| AS/NZS 1170.3 | 2003 | Snow and ice actions |
| AS/NZS 1260 | 2017 | PVC-U pipes and fittings for drain, waste and vent application |
| AS 1397 | 2011 | Continuous hot-dip metallic coated steel sheet and strip - Coatings of zinc and zinc alloyed with aluminium and magnesium |
| AS 1432 | 2004 | Copper tubes for plumbing, gasfitting and drainage applications |
| AS 1530 | | Methods for fire tests on building materials, components and structures |
| AS/NZS 1530.3 | 1999 | Simultaneous determination of ignitability, flame propagation, heat release and smoke release |
| AS 1562 | | Design and installation of sheet roof and wall cladding |
| AS/NZS 1562.3 | 1996 | Plastic |
| AS 1589 | 2001 | Copper and copper alloy waste fittings |
| AS 1631 | 1994 | Cast grey and ductile iron non-pressure pipes and fittings |
| AS/NZS 2179 | | Specifications for rainwater goods, accessories and fasteners |
| AS/NZS 2208 | 1996 | Safety glazing materials in buildings |
| AS 2427 | 2004 | Smoke/heat release vents |
| AS 2665 | 2001 | Smoke/heat venting systems- Design, installation and commissioning |
| AS 3959 | 2009 | Construction of buildings in bushfire prone areas |
| AS 4055 | 2012 | Wind loads for housing |
| AS/NZS 4200.1 | 1994 | Materials |
| AS/NZS 4200.2 | 1994 | Installation requirements |
| AS/NZS 4201 | | Pliable building membranes and underlays - Methods of test |
| AS/NZS 4201.4 | 1994 | Resistance to water penetration |
| AS 4256 | | Plastic roof and wall cladding materials |
| AS/NZS 4256.2 | 1994 | Unplasticized polyvinyl chloride (uPVC) building sheets |
| AS/NZS 4256.3 | 1994 | Glass fibre reinforced polyester (GRP) |
| AS/NZS 4256.5 | 1996 | Polycarbonate |
| SA HB 39 | 2015 | Installation code for metal roof and wall cladding |
| SAA HB 106 | 1998 | Guidelines for design of structures in snow areas |
| SAA/SNZ HB 114 | 1998 | Guidelines for design of eaves and box gutters |
| ABCB Condensation | 2014 | Condensation in buildings handbook |
| BCA 3.12.1.3 | 2016 | Acceptable construction - Energy efficiency - Building fabric - Roof lights |
| BCA Spec C1.10 | 2016 | Fire resistance - Fire hazard properties |
| BCA J1.4 | 2016 | Energy efficiency - Building fabric - Roof lights |
| BlueScope TB-01A | 2016 | Steel roofing products - Selection guide |
| NATSPEC DES 004 | 2005 | Air, moisture and condensation |
| NATSPEC DES 010 | 2009 | Atmospheric corrosivity categories for ferrous products |
| NATSPEC DES 011 | 2007 | Rainwater harvesting |
| NATSPEC DES 018 | 2008 | Bushfire protection |
| NATSPEC DES 020 | 2011 | Fire behaviour of building materials and assemblies |
| NATSPEC DES 031 | 2014 | Specifying R-Values |
| NATSPEC GEN 006 | 2007 | Product specifying and substitution |
| NATSPEC GEN 024 | 2015 | Using NATSPEC selections schedules |
| NATSPEC TR 01 | 2016 | Specifying ESD |